

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7300-1408:111 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Signal Communications Corporation, 4 Wheeling Ave., Woburn, MA 01801
Contact: Nadim Farhat (781) 933-0998 Fax (781) 933-5019

DESIGN: Models AU-360-ES, AU-367-ES, AU-380-ES and AU-387-ES slave amplifier modules; Model AU-388-CPI control panel interface module; Model AU-586-I distributed audio interface module; Model AU-571-U tone generator; Model AU-340P power supply/battery charger and Model AU-DM digital message repeater. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances, NFPA 72 and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation and UL label.

APPROVAL: Listed as voice communication accessories for use with separately listed compatible Model AU-360 (CSFM Listing No. 6912-1408:108) voice evacuation/communication system.

NOTE: Formerly 7300-1083:104

05-10-99



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager